



NC Sturgeon Safety Management System			Doc No:	FIREEXT
			Initial Issue Date	03/2016
FIRE PROTECTION/ EXTINGUISHERS			Revision Date:	Initial Version
			Revision No.	0
			Next Revision Date:	TBD
Preparation: Safety Mgr	Authority: President	Issuing Dept: Safety	Page:	Page 1 of 3

Purpose

The purpose of this program is to provide fire extinguisher procedures to ensure equipment is operable and employees have the knowledge to safely operate in case of a fire incident.

Scope

Applies to all COMPANY employees and all **NC Sturgeon** locations.

Responsibilities

The Safety Manager is responsible for developing procedures for the use and care of fire extinguishers and for developing a training program for the proper use of these devices. The Manager is responsible for implementing fire extinguisher training at his location. The shop foremen are responsible for enforcing the provisions of this section of the safety manual. All employees are responsible for following these provisions.

Procedure

Selection and Distribution

Portable fire extinguishers shall be provided for employee use and selected and distributed based on the classes of anticipated workplace fires and on the size and degree of the hazard which would affect their use. Fire extinguishers used by this company are for four classes of fires:

- Class A Fire Extinguishers. Use on ordinary combustibles or fibrous material, such as wood, paper, cloth, rubber and some plastics. Travel distance for employees to any extinguisher is 75 feet (22.9 m) or less.
- Class B Fire Extinguishers. Use on flammable or combustible liquids such as gasoline, kerosene, paint, paint thinners and propane. Travel distance from the Class B hazard area to any extinguisher is 50 feet (15.2 m) or less.
- Class C Fire Extinguishers. Use on energized electrical equipment, such as appliances, switches, panel boxes and power tools. Travel distance from the Class C hazard area to any extinguishing agent is 50 feet (15.2 m) or less.
- Class D Fire Extinguishers. Use on combustible metals, such as magnesium, titanium, potassium and sodium. Travel distance from the combustible metal working area to any extinguishing agent is 75 feet (22.9 m) or less.

Labelling Of Fire Extinguishers

Fire extinguishers are to be mounted in easily accessible locations that are indicated by a sign that reads "Fire Extinguisher". Fire extinguishers are to be located so that no employee will ever be more than 75 feet from an extinguisher. No equipment, boxes or product may be placed (even temporarily) in the way of a fire extinguisher. Each fire extinguisher will be assigned a unique number.



NC Sturgeon Safety Management System			Doc No:	FIREEXT
			Initial Issue Date	03/2016
FIRE PROTECTION/ EXTINGUISHERS			Revision Date:	Initial Version
			Revision No.	0
			Next Revision Date:	TBD
Preparation: Safety Mgr	Authority: President	Issuing Dept: Safety	Page:	Page 2 of 3

Maintenance

All fire extinguishers shall be mounted no higher and no lower than four (4) feet from the floor. All fire extinguishers shall be maintained as follows:

- Numbered to identify their proper location
- Fully charged and in operable condition
- Clean and free of defects
- Readily accessible at all times

Inspection, Maintenance and Testing

All fire extinguishers are to be visually inspected by **NC Sturgeon** employees monthly. All fire extinguishers are to receive an annual maintenance check by certified personnel from a fire extinguisher dealer. Fire extinguishers are to be inspected and re-charged by certified personnel after any use.

Any fire extinguisher that shows a loss of pressure during the monthly inspection will be inspected and re-charged by certified personnel. Completed fire extinguisher inspection logs will be maintained in the safety files and become a part of the safety records. They are to be maintained for 5 years.

Use

In the event of a fire, one employee will get the nearest fire extinguisher and use it to attempt to put the fire out. All other employees in the immediate area will prepare to evacuate if needed. All other employees in the building need to be advised that a fire is in progress.

The employee attempting to extinguish the fire will break the safety seal on the handle and pull the pin. He will then aim his extinguisher at the base of the fire and discharge it with a sweeping motion from side to side; continuing until the fire is out or the extinguisher is emptied.

Remember that a standard fire extinguisher will be emptied in about 10 to 15 seconds. If the fire is not out when the extinguisher has been completely discharged, the employees must evacuate the area.

Training and Education

The purpose of this section is to establish training procedures which are necessary for the proper use and understanding of a fire extinguisher and incipient stage fire fighting. Training will occur prior to initial assignment and at least annually thereafter.

On even numbered years this training will be conducted by a member of the local fire department (where possible) and will include "live fire" hands on use of the extinguisher. On odd number years this training will be conducted by the Safety Manager and will include a demonstration of the use of a fire extinguisher, without actually discharging the unit.

New employees will be given the odd number year training upon hire.

Initial Training Outline

- General principles of a fire



NC Sturgeon Safety Management System		Doc No:	FIREEXT
		Initial Issue Date	03/2016
FIRE PROTECTION/ EXTINGUISHERS		Revision Date:	Initial Version
		Revision No.	0
		Next Revision Date:	TBD
Preparation: Safety Mgr	Authority: President	Issuing Dept: Safety	Page: Page 3 of 3

- Hazards employed with an incipient stage fire(s)
- When to "back off' (evacuate) of an incipient stage fire(s)
- General fire principles of a fire extinguisher
- Hazards employed with the use a fire extinguisher
- Use of a fire extinguisher

Retraining

Retraining shall reestablish employee proficiency and introduce new or revised control methods and procedures, as necessary. Retraining shall be provided for all authorized and affected employees whenever there is:

- An annual basis or
- A change in job assignment or
- **NC Sturgeon** has reason to believe that there are deviations from or inadequacies in the employee's knowledge or use of fire extinguishers or fire prevention procedures.

Training Documentation

- All training will be documented and each employee's understanding will be subject to a "hands-on" test.
- Documentation will consist of; as a minimum, the employee's name, the trainer's name, the date of the training, and an outline of training provided.